

November 22, 2016

CH 1679705:1 **Coliform Bacteria Analysis**

Customer ID : 7009457

Almanor Heights Mutual Water Co.

Attn: John Fourcroy

2737 Scott Dr

Prattville, CA 95923

System Number : 3200139

Project Name : Routine Monitoring

Analytical Results

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	2713 Scott Drive FF	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

The samples listed above were Acceptable for both Total and Fecal Coliform

Sample Handling Information

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	CH 1679705-001	3200139	System-Routine	Stephen Semple	FGL Environmental	2016-11-16 10:41

Field Analysis/QA Information

ID	Sample Description	Cl Total/Free mg/l	Temp	Analysis Started	Analysis Completed	Contact	Contacted
1	2713 Scott Drive FF	---/---	---	2016-11-16 15:30 pKx	2016-11-17 10:01 SMK	N/R	


Analyses were performed at the FGL Chico Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call.

Prepared By: GMA

cc:PCEH

Reviewed and
Approved By

Raquel R. Harvey

 Digitally signed by Raquel R. Harvey
Title: Tech Director Microbiology
Date: 2016-11-22